

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 5
77 WEST JACKSON BOULEVARD
CHICAGO, ILLINOIS 60604

DATE: **JAN 29 2016**

SUBJECT: CLEAN AIR ACT INSPECTION REPORT
Buckeye Terminal, Inc., East Chicago, Indiana

FROM: Gina Harrison, Environmental Scientist
AECAB (MN/OH)

THRU: Brian Dickens, Section Chief
AECAB (MN/OH)

TO: File

BASIC INFORMATION

Facility Name: Buckeye Terminal, Inc.

Facility Location: 3821 Indianapolis Boulevard Terminal, East Chicago, Indiana, 46312

Date of Inspection: June 11, 2013

Lead Inspector: Gina Harrison, Environmental Scientist

Other Attendees:

1. Shilpa Patel, EPA, Environmental Engineer
2. Nick Spite, Buckeye, Operations Manager
3. T. Andy Baldwin, Buckeye, Assistant Operations Manager

Purpose of Inspection: Tanks inspection

Facility Type: Tank Farm

Arrival Time: 10:15 AM

Departure Time: 1:20 PM

Inspection Type:

- ☒ Unannounced Inspection
☐ Announced Inspection

OPENING CONFERENCE

- ☒ Credentials Presented
- ☒ CBI warning to facility provided

The following information was obtained verbally from Mr. Spite and Mr. Baldwinbuck unless otherwise noted.

Process Description:

Buckeye's Indianapolis Boulevard terminal stores gasoline, propylene and petroleum products for oil and refineries. The terminal has 23 active tanks. The propylene storage tanks and loading rack are controlled by a portable vapor control unit. The vapor pressure is tested as the material enters and leaves the facility.

TOUR INFORMATION

EPA toured the facility: Yes

Data Collected and Observations:

5 tanks were observed with the IR camera. No pictures or vidoes were taken.

Field Measurements: were not taken during this inspection.

RECORDS REVIEW

- Plant Site Map
- E-10 Gasoline RVP VOC Phase-Down Guidelines

SIGNATURES

Lead Inspector: Shifu Patel for Gae Harrison Date: 1/29/10

Section Chief: Johnnie Dickers for Brian Date: 1/29/10